

**Richmond Building Regulation Bylaw 7230
(amended by Bylaw 8542, December 14, 2009)**

- Clause 6.1.1 says “In addition to the requirements of the building code, a crawl space floor must be finished with a continuous membrane of an approved moisture-resistant material beneath a continuous layer of concrete having a thickness of at least 50 millimeters.”